SEMAC-D1

WEB Configuration Manual

[Contents]

Logon WEB	1
Premise	1
WEB IE Browser	1
Main Window (Terminal Status)	2
Illustration of Terminal Status Screen	
mustration of forminal status sereen	
User Administration	4
Log/Report	
Illustration of Access Log	
Auto Refresh Log	6
View User List	6
Illustration of User List	
Modify User Record	
Modify User List in "View User List"	9
Add User	10
Illustration of Add New User	11
Terminal	12
Terminal Status	
Illustration of Terminal Status	
Terminal Setup	14
Illustration of Terminal Configuration	
Password Setup	
Illustration of WEB Logon Setting/Entrance Password	18
System Log	20
Illustration of System Log	20
Clock Setup	21
Illustration of System Clock Setup	21
Access Control	22
Time Set	22
Illustration of Time Set	22
Time Zone Setup	23
Illustration of Time Zone List	23
Illustration of Time Zone Information	24
Group List	25

	Illustration of Group List	25
	Illustration of Group Information	26
	Holiday Setup	27
	Illustration of Holiday Setup	27
	Door Setup	28
	Illustration of Door Setting	29
	Illustrations of Door 1 Setting in Door Setup	32
	Remote Control	35
	Illustrations of Door Status Monitoring/Security Bypass	
	Event Handle	37
	Illustration of Event Handle	38
	Multi Badge Group	42
	Illustration of Multi Badge Group.	42
TO	OOLS	
	IP Camera	43
	Illustration of IP Camera.	43
	Backup	43
	Restore	44
	Reboot	
	Illustration of Reboot.	44
	Upgrade Firmware	45
	Illustration of Upgrade Firmware	
	Reset	46
	III 4 4: CD 4	1.0

-WEB Configuration -

SEMAC-D1 WEB Configuration

♦ Logon WEB

SEMAC-D1 is with built-in HTTP server for using WEB IE Browser to connect SEMAC-D1 and execute the settings of SEMAC-D1.

♦ Premise

Please make sure the following points before your SEMAC-D1 settings:

- Your PC computer may build up a physical connection with SEMAC-D1, meanwhile, both of your computer and the SEMAC-D1 are within the same Network Segment.
- SEMAC-D1 has been installed and with power.
- Should the default IP address of SEMAC-D1 (192.168.0.66) has been occupied by other devices, you have to shut down all the other devices until the setting completed. Then a new IP address will be distributed to the SEMAC-D1.

◆ WEB IE Browser

- 1 · Start the WEB IE Browser first.
- 2 Enter the http:// and the IP address of SEMAC-D1 in the address bar. For example, enter the default IP address of SEMAC-D1: http://192.168.0.66.

Communication failure:

When no feedback from the SEMAC-D1, please check as below:

- Is the SEMAC-D1 installed properly, the local area network (LAN) connected well or the power connected fine? Try to use the "ping" command to test the communication status of SEMAC-D1 IP address by the following steps:
 - Open a MS-DOS window, or a command window;
 - Input your command: ping 192.168.0.66,

For example: C:\user\tank>ping 192.168.0.66

If no any response, it indicated abnormal connection or the PC computer IP address in conflict or not match with SEMAC-D1 IP address (referring to next paragraph).

- If a PC computer with a Static IP/Fixed IP, the IP range should be defined between 192.168.0.1~ 192.168.0.65 or 192.168.0.67~192.168.0.254. So the PC computer IP may be compatible with the default IP address of SEMAC-D1, 192.168.0.66. Moreover, the Subnet Mask should be as 255.255.255.0 ∘
- To make sure both your PC computer and the SEMAC-D1 in the same Network Segment.

➤ Main Window (Terminal Status)

When installation completed and well connected with SEMAC-D1, the "Terminal Status" window will be pop-up. It will show after the following connection frequently as following illustration:

TERMINAL STATUS

Product Name :	SEMAC-D1(20000)
Serial No. :	036fdc(113222)
Firmware Version :	1.00.00,Dec 23 2013(HW1.1)
System Time :	02/11/2014 10:55:50
Terminal ID(MAC Address):	1(00:0e:e3:03:8f:dc)
IP Address :	192.168.2.67
Subnet mask :	255.255.255.0
Default Gateway :	192.168.2.1
Primary DNS:	168.95.1.1
Listen Port/Software IP(status):	2000/0.0.0.0(Offline)
Web Management Port :	67
Registered User:	0
Available User Capacity :	20000
Access/System Log Count:	0/8
Reader Type :	WG34
Anti-Pass-Back(Tolerance Timer) :	Disabled(0)
Anti-Duress:	Disabled
Next SEMAC(status):	0.0.0.0(Offline)

♦ Illustration of Terminal Status Screen

Browse the Function Bar left side :

► User Administration	n	
Log/Report	Switch to the "Access Log" screen to check, search, export log reports	
Auto Refresh Log	uto Refresh Log Press the button to refresh system to get new logs	
77: TI T:-4	Switch to the "User List" screen to	
View User List	Search/Modify/Delete/Deactivate/Activate user data	
Add User	Switch to the "User Record" screen and input user data on the "Add	
Add User	New User "screen	
▶ Terminal		
Terminal Status	Switch to the "Terminal Status" screen (Main Window)	
Terminal Setup	Switch to the "Terminal Configuration" screen to input data	
Password Setup	Switch to the "WEB Logon Setting" and "Entrance Password" screen.	
System Log	Switch to the "System Log" screen.	
Clock Setup	Switch to the "System Clock Setup" screen.	
► Access Control		
Time Set	Switch to the "Time Set" screen.	
Time Zone Setup	Switch to the "Time Zone List" screen.	
Group List	List Switch to the "Group List" screen.	
Holiday Setup Switch to the "Holiday Setup" screen.		
Door Setup	Switch to the "Door Setting" screen.	
Remote Control	Switch to the "Door Status Monitoring" and "Security Bypass" screen.	
Event Handle	Switch to the "Event Handle" screen.	
Multi Badge Group	Switch to the "Multi Badge Group" screen.	
▶ Tools		
IP Camera	Switch to the "IP Camera Configuration" screen.	
Backup	Switch to Backup screen	
Restore	Switch to Restore screen	
Reboot	Switch to the "Reboot System" screen.	
Upgrade Firmware	Switch to the "Firmware Upgrade" screen.	
Reset	Switch to the "Reset" screen.	
▶ Button		
Refresh	Refresh the WEB Status.	

> User Administration


♦ Log/Report

Select"Access Control" on the Main Window, you'll see the "Access Log/Query and Export"screen as the following picture:

Access Log/Query and Export

No.	User ID	User Name	Date	Time	IN/OUT	Door	Note.
			No Log Data	1			

Query and Export



♦ Illustration of Access Log

► Query (BY)		
Type	By User or Event	
Selection	Single or All	
Start / End Date	From – To Date period input	
User ID	Input User ID or Card No. (in Decimal format)	
Export Type	Text (txt) or Excel (xls) format	
► Access Records Illus	tration by Columns	
No.	Serial Number	
User ID	A system User ID assigned for the user to access door(s). Click the "User ID" to enter the page of "User Record" and "Modify User Record". ** The figure in the parentheses () after the "User ID" is indicated the user's Bypass TZ level as 1~10	
User Name	User name has registered to the current system	
Date	A date period allowed user(s) to access door(s)	
Time	A Time allowed for the User to get IN/OUT.	
IN/OUT	IN: Open the door by punching card at the outside of door reader to get IN records OUT: Open the door by pressing push button inside of a door to get OUT records * The figure in the parentheses () after the "IN/OUT" record indicated APB (Anti Pass Back) level.	
Door	Indicating the Door Number controlled by SEMAC-D1.	
Note	Show up the relative IN/OUT records automatically as Anti-Duress, Fire Alarmetc.	
the First Page	Back to the 1st IN/OUT records page.	
the Former10 pages	Forwarding 10 pages from the current IN/OUT records page.	
1 2 3N page	Change to any IN/OUT records page assigned.	
the Latter 10 pages	Backwards 10 pages from the current IN/OUT records page.	
the Last Page	Fly to the last IN/OUT records page directly.	

♦ Auto Refresh Log


Auto Refresh Log Wed Feb 05 2014 17:52:31 GMT+0800 (台北標準時間)

No.	User ID	User Name	Date	Time	IN/OUT Door	Note.

♦ View User List

Select"View User List" on the Main Window, you'll see the "User List" screen as the following picture:

User List



♦ Illustration of User List

► Search User By		
By "User ID"	Select "User ID" and Enter your "User ID" in the textbox to search.	
By "Card	Select "Card No." and Enter your "Card No." in the textbox to search.	
No."(DEC)		
By "User Name"	Select "User Name." and Enter your "User Name" in the textbox to search.	
Click "GO" Button	Start to search.	

Steps:

- 1 ${\boldsymbol \cdot}$ Enter your "User ID", "Card No." or "User Name" in the "blank textbox"
- 2 · Click button "GO" to search.


▶ User List	► User List		
	Serial Number. Tick the box before the "Serial Number" and Click the		
No	button of "Activate", "Deactivate" or "Delete" to manage the		
No.	authorization of "Activate", "Deactivate" or "Delete" for selected users,		
	multi-selection is allowed.		
User ID	User's ID. Click the "User ID" to enter the "Modify User Record" page.		
User Name	Display User Name in the system.		
	Types of the User. Whenever the "User Type" is set up in the screen of		
User Type	"Modify User Record", this page will display Normal User, Super User,		
	Visitor, Guard Touring and Defense Card according to the setup.		
Activo	Display the user's authorization status. Green Light indicated the user's		
Active	door access authority is being activated, otherwise it is not activated.		
P	When the user's Personal Password registered, this column will be with		
r	Green Light.		
C	When the user's card registered, this column will be with Green Light.		
Bypass Level	Display the user's Time Zone level of Bypass from L1~L10.		
the First Page	Back to the 1st page of "User List".		
the Former10	Forwarding 10 pages from the current "Hear List" page		
pages	Forwarding 10 pages from the current "User List" page.		
1 2 3N page	Change to any "User List" page assigned.		
the Latter 10 pages	Backwards 10 pages from the current "User List" page.		
the Last Page	Fly to the last "User List" page directly.		
▶Button			
Activate	Activate the User's authorization.		
Deactivate	Deactivate the User's authorization.		
Delete	Delete the User's information registered.		

♦ Modify User Record

Select "Modify User Record" on the Main Window, you'll see the "User Record" screen as following picture:

User Record

Modify User Record



♦ Modify User List in "View User List"

▶ User Record		
User ID	Self-define User ID from number 1~20,000 is allowed only.	
Card Na	Manual input card no. in decimal format (when any card decoder installed,	
Card No.	card no. can be read automatically)	
Name	Input User's Name (max. 31 characters)	
Expire Date Check	Enable or Disable user's authority expire date check	
Effective	When "Expire Date Check" enabled. It requires to enter a period of date	
From ~To	time.	
Status	"Activate" or "Deactivate" user access authority for system	
	Card Types of the User. The "Drop Down Menu" will list out cards for	
	Normal User, Super User, Visitor, Guard Touring, Defense Card,	
	Manager Card-Add and Manager-Card-Delete as your choice. The	
	Respective definitions are as below:	
	Normal User: System default type for common users.	
	Super User Card: Not constrained by APB (Anti Pass Back) rule.	
	Visitor Card: Program visitor cards with certain date access permission	
User Type	(expired date check)	
	Guard Touring Card: Door won't open when Guard Touring card	
	punched but log will be kept on system.	
	Defense Card: When the card sweeps the door, all the doors will activate	
	Access Control at once. Any type of cards cannot access	
	the door until the Defense Card punch again to restore	
	normal functions.	
	Each user can be assigned to 4 different groups. All of the group names	
Group	existed will be automatically listed out by the "Drop Down Menu" for your	
Отопр	choice. "Free Time Group" is a "Default Group".	
	The "Bypass Time Zone Level" of each user is from L1~L10.	
	When user's Bypass TZ level >Door Bypass TZ Level, User may access	
Bypass TZ Level	door by card only. When user's Bypass TZ level < Door's Bypass TZ level,	
	user should access the door by door's setup bypass level.	
Personal Password		
Personal Confirm	Reconfirm Personal Password.	
▶ Button		
Previous	Modify previous user record.	
Save	Save the modified user record.	
Delete	Delete existing user record.	
Next	Modify next user record.	

♦ Add User

Select"Add User" on the Main Window, you'll see the User Record "screen for Add New User as the following picture:

Add New User	
REG: Si	ngle 🔾 Continuous Amount :
User ID :	(1 ~ 20000)
Card No. :	(DEC)
Name :	(Max 31 chars.)
Expire Date Check : Dis	able Enable
From	2014 V (Y) 02 V (M) 06 V (D) 15 (H) 0 (M)
То	$2014 \lor (Y) 02 \lor (M) 06 \lor (D) 15 (H) 0 (M)$
	tivate O Deactivate
User Type : Norma	
	e Time Group \checkmark 2. Disallowed Group \checkmark 3. Disallowed Group \checkmark 4. Disallowed Group \checkmark
	<u> </u>
Personal Password :	(4 ~ 8 digits.)
Personal Confirm :	
	Save

♦ Illustration of Add New User

▶ User Record		
	Single: Only one user can be registered each time.	
REG	Continuous: It allows you to register 1~20000 users continually. You	
REG	may input required q'ty in the textbox of Amount. However,	
	only the serial number is accepted and supported.	
User ID	Self-define User ID from number 1~20,000 is allowed only.	
Card No	Manual input card no. in decimal format (when any card decoder	
Card No.	installed, card no. can be read automatically)	
Name	Input User's Name (max. 31 characters)	
Expire Date Check	Enable or Disable user's authority expire date check	
Effective	When "Expire Date Check" enabled. It requires to enter a period of date	
From ~To	time.	
Status	"Activate" or "Deactivate" user access authority for system	
	Card Types of the User. The "Drop Down Menu" will list out cards for	
	Normal User, Super User, Visitor, Guard Touring, Defense Card,	
	Manager Card-Add and Manager-Card-Delete as your choice. The	
	Respective definitions are as below:	
	Normal User: System default type for common users.	
	Super User Card: Not constrained by APB (Anti Pass Back) rule.	
User Type	Visitor Card: Program visitor cards with certain date access permission	
Oser Type	(expired date check)	
	Guard Touring Card: Door won't open when Guard Touring card	
	punched but log will be kept on system.	
	Defense Card: When the card sweeps the door, all the doors will activate	
	Access Control at once. Any type of cards cannot access	
	the door until the Defense Card punch again to	
	restore normal functions.	
	Each user can be assigned to 4 different groups. All of the group names	
Group	existed will be automatically listed out by the "Drop Down Menu" for	
	your choice. "Free Time Group" is a "Default Group".	
	The "Bypass Time Zone Level" of each user is from L1~L10.	
Bypass TZ Level	When user's Bypass TZ level >Door Bypass TZ Level, User may access	
bypass 12 Level	door by card only. When user's Bypass TZ level < Door's Bypass TZ	
	level, user should access the door by door's setup bypass level.	
Personal Password	4~8 digits allow only	
Personal Confirm	Reconfirm Personal Password.	
▶ Button		
Save	Save user records.	

> Terminal

♦ Terminal Status

Select and Click"Terminal Status" on the left side of the Main Window, you'll see the "Terminal Status" screen. This screen is the Main Window for Logon. It displays the current Terminal Status and relative information of WEB setup, referring to the following picture:

TERMINAL STATUS

Product Name :	SEMAC-D1(20000)
Serial No. :	036fdc(113222)
Firmware Version :	1.00.00,Dec 23 2013(HW1.1)
System Time :	02/11/2014 10:55:50
Terminal ID(MAC Address) :	1(00:0e:e3:03:8f:dc)
IP Address :	192.168.2.67
Subnet mask :	255.255.255.0
Default Gateway :	192.168.2.1
Primary DNS:	168.95.1.1
Listen Port/Software IP(status) :	2000/0.0.0.0(Offline)
Web Management Port :	67
Registered User :	0
Available User Capacity :	20000
Access/System Log Count :	0/8
Reader Type :	WG34
Anti-Pass-Back(Tolerance Timer) :	Disabled(0)
Anti-Duress :	Disabled
Next SEMAC(status):	0.0.0.0(Offline)

♦ Illustration of Terminal Status

▶ Terminal Status	
Product Name	Model Number of SEMAC-D1
Serial No.	Serial Number of SEMAC-D1
Firmware Version	Firmware and Hardware Version of SEMAC-D1
System Time	System Time of SEMAC-D1
Terminal ID	Terminal ID and MAC address of SEMAC-D1
(MAC Address)	Terminal ID and Wife address of SEWITE DI
IP Address	Current IP address of SECMAC-D1
Subnet mask	Subnet mask of SEMAC-D1
Default Gateway	Default Gateway address of SEMAC-D1
Primary DNS	Primary DNS address of SEMAC-D1
Listen Port/Software	Listen Port and Networking Software IP address (status : Online or
IP(status)	Offline)
WEB Management	WEB communication number of SEMAC-D1
Port	WED communication number of SEIVERCE BY
Registered User	Registered user number of SEMAC-D1
	Available Capacity of SEMAC-D1 to register users;
Available User Capacity	Available user number(s) to be registered=
	Sum (20000)—Registered user(s)
Access/	The Sum from access and system logs of SEMAC-D1
System Log Count	The Sum from access and system logs of SENIAC-DI
Reader Type	Indicated connected reader format (default is WG34)
Anti-Pass-Back	Current APB status (Enable or Disable) on SEMAC-D1, indicating
(Tolerance Time)	with (APB Tolerance Time)
Anti-Duress	Current Anti-Duress status (Enable or Disable) on SEMAC-D1.
	IP Address of Next SEMAC-D1 which interaction with first APB
Next SEMAC(status)	(anti pass-back) function and Fire Alarm door emergency open. Also
	indicating with connectivity status (Online or Offline)

♦ Terminal Setup

Select and Click"Terminal Setup" on the left side of the Main Window, you'll see the "Terminal Configuration", referring to the following picture:

Terminal Configuration

Terminal Setting :	Terminal ID: 1
	*IP Address : 192 . 168 . 2 . 68
	*Subnet Mask : 255 . 255 . 0
	*Gateway: 192 . 168 . 2 . 1
	*DNS Server: 168 . 95 . 1 . 1
Software:	*TCP Port(Software Used) : 2000 *Software IP : 192.168.2.182
Web Language:	English V
Anti Pass Back :	○ Enable ○ Anti Follow ● Disable
	Tolerance Timer 0 (Minute, Maximum 65535, 0 means No Tolerance)
Anti Duressed :	○ Enable ● Disable
	Password • (Max 3 digits,default is 9)
WEB Managemant Port :	Http Port: 68
Next SEMAC(for APB):	IP Address: 0 . 0 . 0 . 0
Fast Reg Card Mode :	○ Enable
	Terminal may need to restart after configuration saved.
	SAVE

♦ Illustration of Terminal Configuration

► Terminal Co	nfiguration
Terminal	Setting Tempinal ID for summer SEMAC D1 Default ID-1 may 65 525
Setting:	Setting Terminal ID for current SEMAC-D1. Default ID=1, max. 65,535
Terminal ID	(Terminal ID should not be duplicated in one system)
IP Address	Setting IP Address of SEMAC-D1.
Subnet Mask	Setting Subnet Mask of SEMAC-D1
Gateway	Setting Default Gateway of SEMAC-D1
DNS Server	Setting the DNS Server IP Address of SEMAC-D1. Default DNS Server IP
IP Address	Address is 168.95.1.1.
▶ Software	
TCP Port (Software	Setting a TCP Port for Software to communicate with SEMAC-D1.
Used)	Default TCP Port No. is 2000
Software IP	For setting the Software IP to communicate with SEMAC-D1 Default Software IP is 0.0.0.0.
▶ Web Langua	ge
English	When you choose the" English" language from the "Drop Down Menu", the WEB page of SEMAC-D1 will be switched to "English" interface.
Chs	When you choose the" Chs" language from the "Drop Down Menu", the WEB page of SEMAC-D1 will be switched to "Simplified Chinese" interface.
Others	When you choose "Others" from the "Drop Down Menu", the WEB page of SEMAC-D1 will be switched to "Traditional Chinese" interface or other languages.
► Anti Pass Ba	
Enable	Tick this circle to enable the "APB" (Anti Pass Pack) function.
Anti Follow	Automatically set all door(s) with APB level: Entry (IN): 1, Exit (OUT):2. User should access door only from Entry side then exit from Exit side.
Disable	Tick this circle to disable the "APB" (Anti Pass Pack) function.
Tolerance Time	Set a time that system will be restored to original status after "APB" triggered. The unit of time can be 0~65535(minute). For value set to "0" which indicated APB function will not be restored to normal after certain time until manually disable "APB" function. (Default value=0)
► Anti Duress	
Enable	Tick this circle to enable the "Anti Duress" function.
Disable	Tick this circle to disable the "Anti Duress" function.
Password	Set a set of password for "Anti Duress" function. Default value = 9, max. 3 digits.

▶ WEB Mana	gement Port
Http Port	Set your WEB communication port for SEMAC-D1, default value=80.
► Next SEMA	C(for APB)
ID Address	Set IP address for Next SEMAC-D1. All the APB level setting from first
IP Address	SEMAC-D1 will be copied to next SEMAC-D1.
▶Button	
Save	Save the Terminal configuration settings.



♦ Password Setup

Select "Password Setup" on the left side of the Main Window, you'll see the "WEB Logon Setting/Entrance Password" screen, referring to the following picture:

WEB Logon Setting



Entrance Password

Administrator Password : $(4 \sim 8 \text{ digits.})$ Common Password : 12345 $(4 \sim 8 \text{ digits.})$ SAVE

♦ Illustration of WEB Logon Setting/Entrance Password

► WEB Logon Setting	
Administrator WEB Logon	Input the required Administrator's logon user name for WEB
User Name	management, max. 47 characters, default value: "admin".
Administrator WEB	Input the required Administrator's logon password for WEB
Logon Password	management, max. 35 digits, default value: "admin".
Operator WEB Logon	Input the required Operator's logon user name for WEB
User Name	management, max. 47 characters, default value: "user".
Operator WEB Logon	Input the required Operator's logon password for WEB
Password	management, max. 35 digits, default value: "user".
User WEB Logon User	Input the required User's logon user name for WEB
Name	management, max. 47 characters, default value: "user0".
II. WED I D I	Input the required User's logon user name for WEB
User WEB Logon Password	management, max. 35 digits, default value: "user0".
The Administrator, Operator ar	nd User have their respective authorizations, referring to the
following "Authorization Table	3".
▶ Button	
Save	Save all the WEB Logon Settings.
► Entrance Password	
	Set your "Common Password" here. Meanwhile, you have
	to select "001 Any Time "for "Common Password Time
	Zone "simultaneously to support this setting (for example:
Common Password	Door Setup→Door Setting→Click "Door1"→Door 1 Setting→
	Select "Common Password Time Zone "→ Select "001 Any
	Time "from the "Drop Down Menu").
	Default value: "1234".
▶ Button	
Save	Save the Password setting.

Authorizations Table ("•" = Access Permission)

	Administrator	Operator	User
WEB Function	User Name: admin	User Name: user	User Name: user0
	Password: admin	Password: user	Password: user0
Upgrade Firmware	•		
Password Setup	•		
Terminal Setup	•		
Door Setup	•		
Event Handle	•		
Reboot	•		
Clock Setup	•		
Reset	•		
Upgrade Firmware	•		
Password Setup	•		
Terminal Setup	•		
User Data	•	•	
Time Set		•	
Time Zone Setup		•	
Group List	•		
Holiday Setup	•	•	
Multi Badge Group	•	•	
Remote Control	•	•	
Access Log		•	•
View User List	•	•	•
Terminal Status	•	•	•
System Log	•	•	•
IP Camera	•	•	•

♦ System Log

Select "System Log" on the left side of the Main Window, you'll see "System Log "screen as the following picture:

System Log

Time 16:08:32 16:39:17	System Power ON System Warm Start	Description		
16:39:17	System Warm Start			
16:39:16	System Terminal Setup from Web			
16:38:54	System Warm Start			
16:37:30	System Power ON			
16:06:01	ETH Dev Link Down			
1	6:37:30	6:37:30 System Power ON	6:37:30 System Power ON	6:37:30 System Power ON

♦ Illustration of System Log

► System Log	
No.	Serial Number of the log
Date	Date of the log
Time	Time of the log
Description	Description of the system operation records
* Max. logs capac	eity: 1536 entries, for checking by authorized person(s) only, no logs export
provide.	

♦ Clock Setup

Select and Click "Clock Setup" on the left side of the Main Window, you'll see the "System Clock Setup" screen, referring to the following picture:

SYSTEM CLOCK SETUP

Time Server :	Disable	
	time.windows.com	Recommend: time.windows.com or time.nist.gov
Time Zone:	(GMT+08:00) China, Hong Kong, Australia Western	v
	SA	VE
	New Date : 09/15/2009	(mm/dd/yyyy)
	New Time: 13:47:51	(hh:mm:ss)
	SAVE	

♦ Illustration of System Clock Setup

▶ Time Server	
Disable	Tick this circle to shut up the Time Server network connection.
Enable	Tick this circle to start the Time Server network connection.
Time Zone	The "Drop Down Menu" offers you all the Time Zones available up to your
Time Zone	option, default time zone : (GMT)England.
"Save" button	Save the Time Server Settings and adjust the time.
When enable the "Tir	me Server", please key in the IP address or http:// of the "Time Server".
Then select the requi	red Time Zone and Save it to connect the "Time Server" for a time
adjustment.	
New Date	The date of networked PC computer. You may adjust the date to your
New Date	requirement as the format of "mm/dd/yyyy".
New Time	The date of networked PC computer. You may adjust the time to your
New Time	requirement as the format of "hh:mm:ss".
"Coyo" button	Save the configuration of this page and upgrade the date/time for the
"Save" button	networked PC computer.

> Access Control

♦ Time Set

Select and Click "Time Set" on the left side of the Main Window, you'll see the "Time Set" screen, referring to the following picture:

Time Set

000	00:00 ~ 00:00		004	00:00 ~ 23:59	
000	00:00 ~ 00:00		001	00:00 ~ 25:59	
002	04:00~17:00	DELETE	003	18:00~23:00	DELETE
004	02:00~05:30	DELETE	005	15:00~19:00	DELETE
006	16:00~19:00	DELETE	007	07:00~16:00	DELETE
800	17:30~21:30	DELETE	009	03:45~09:30	DELETE
010	10:00~14:00	DELETE	011	09:00~17:00	DELETE
012	17:00~22:00	DELETE	013	00:00~13:00	DELETE
014	19:00~23:00	DELETE	015	07:30~15:00	DELETE
016	16:00~20:00	DELETE	017	12:58~19:56	DELETE
018	12:58~18:59	DELETE	019	02:00~08:00	DELETE
020	03:00~05:00	DELETE	021	07:00~13:00	DELETE

Time Set: 022 From 00 H: 00 M To 23 H: 59 M SET

♦ Illustration of Time Set

▶ Time Set List		
Time Set List	It will display all the configured time set(s).	
Time Set List	The System Default Time sets are: 00:00~00:00 and 00:00~23:59.	
	Select your time set serial number. The "Drop Down Menu" offers you	
Time Set	all the options for your choice, max. 255 time sets allowed. System built-in	
	values are "000" and "001".	
	Input a time set period, for example: 8:00am to 17:00pm as one period, then	
From ~ To	Time Set: 002 From 00 H: 00 M To 23 H: 59 M SET	
	It is the same way to the others.	
▶ Button		
Delete	Delete an existing "Time Set".	
Set	Add a new "Time Set".	

♦ Time Zone Setup

Select and Click"Time Zone Setup" on the left side of the Main Window, you'll see the "Time Zone List" screen as below:

Time Zone List


Time Zone List:					
000	Deactivate		001	Any Time	
002	<u>2</u>	DELETE	003	<u>3</u>	DELETE
004	<u>4</u>	DELETE	005	<u>5</u>	DELETE

Time Zone ID : 006 V SET


♦ Illustration of Time Zone List

► Time Zone List		
Time Zone List	Display all the Time Zone(s) existing. Click the Time Zone name(indicated	
Time Zone List	as the Time Zone Name example) to enter its Time Zone Information Screen.	
Time Zone ID	Select your Time Zone Serial Number from the "Drop Down Menu", system	
Time Zone ID	built-in numbers as "000" and "001", max. 120 Time Zones allowed.	
Time Zone	Click the name of Time Zone (for example : 2, as below picture) to enter the	
Name	"Time Zone Information" screen for modification.	
▶ Button		
Delete	Delete an existing Time Zone.	
Set	Enter the Time Zone Information screen.	

* Example of "Time Zone Information" screen to show how to set the daily door access and card punching authorized Time Set from Monday to Sunday and Holidays:



♦ Illustration of Time Zone Information



♦ Group List

Select" Group List" on the left side of the Main Window, you'll see the "Group List" screen as below:

Group List

_			
Groun	n I	ici	٠,
Olou	ν,	_ 131	

000	Disallowed Group		001	Free Time Group	
002	2	DELETE	003	<u>3</u>	DELETE
004	4	DELETE			


Group ID: 005 V SET

♦ Illustration of Group List

▶ Group List				
	Display all the Groups configured. Click the Group's name to enter its			
	"Group Information" as below:			
	(for example: click Group Name"4" as picture 14)			
	Group Information			
`	Allowed Door :	Time Zone ID :		
Group List	☑ 1.	002 2		
Group List	☑ 2.	004 4		
	▼ 3.	001 Any Time		
	▼ 4.	003 3		
	<u> </u>	000 Deactivate		
	6.	000 Deactivate		
	☑ 7.	001 Any Time		
	8.	000 Deactivate 💌		
		SAVE		
	Select your "Group ID" by serial number, default values : 000 \ 001.			
Group ID	The "Drop Down Menu "offers you all the serial number of Group ID as			
	options, max. 255 groups allowed.			
▶ Button				
Delete	Delete a Group ID.			
Set	Enter the "Group Information" screen.			

This is a screen to configure the door(s) of a Group ID, referring to the following picture:

Group Information




♦ Illustration of Group Information

► Allowed Door		
	Tick the box of Door 1, then the user(s) assigned to the Group can be	
Door 1	access Door 1 within the "Time Zone ID" indicated, otherwise	
	prohibited.	
Tim Zono ID	The "Drop Down Menu" displays all the "Time Zones" configured in	
Tim Zone ID	the "Time Zone Setup" for option.	
▶Button		
Save	Save the "Group Information".	
Cancel	Cancel or Modify the "Group Information"	

♦ Holiday Setup

Select" Holiday Setup" on the left side of the Main Window, you'll see the "Holiday setup" screen as below:

Holiday setup



♦ Illustration of Holiday Setup

► Holiday Setup		
Month	Select a month from the "Drop Down Menu".	
Date	Select a date from the "Drop Down Menu".	
▶ Button		
Set	Add a new Holiday.	
Delete	Delete a Holiday.	

♦ Door Setup

Select and Click"Door Setup" on the Main Window, you'll see the "Door setting" screen as below:

Door Setting

		Door 1
L10	First Admin Card IN TZ	000
L9	2/3 Badge+Admin P TZ	0(2)/0(2)
L8	2/3 Badge+Personal P TZ	0(2)/0(2)
L7	2/3 Badge TZ	0(2)/0(2)
L6	Card+Admin P TZ	0/0
L5	Admin P TZ	0/0
L4	Card+Personal P TZ	0/0
L3	P TZ	0/0
L2	Card Only TZ	0/0
L1	Card or P TZ	1/1
	Lock Release TZ	000
	Exit Button TZ	001
	APB IN/OUT	0/0
	Multiple Interlocking	N
	Remote Grant Needed	N
	Open Delay Time	10
	Door Open Delay Time	10
	Still Open Delay Time	0
	Degrade Mode	Deactivate
	Log Recorded/Sensor Mode	Y/None

♦ Illustration of Door Setting

▶ Door Setting			
L10 : First Admin	Display the First Admin Cord Di Time Zone from Deer 1		
Card IN TZ	Display the First Admin Card IN Time Zone from Door 1.		
L9: 2/3 Badge	Display the Multiple Badge+ Admin Password Time Zone from Door 1,		
+Admin P TZ	accompanied by a Double or Triple verifications.		
L8: 2/3 Badge	Display the Multiple Badge +Personal Password Time Zone from Door		
+Personal PTZ	1, accompanied by a Double or Triple verifications.		
L7: 2/3 Badge TZ	Display the Multiple Badge Time Zone from Door 1, accompanied by a Double or Triple verifications.		
L6: Card + Admin P TZ	Display the Card +Admin Password Time Zone from Door 1.		
L5: Admin PTZ	Display the Admin Password Time Zone from Door 1.		
L4: Card + Personal TZ	Display the Card +Personal Password Time Zone from Door 1.		
L3: Common Password TZ	Display the Common Password Time Zone from Door 1.		
L2: Card Only TZ	Display the Card Only Time Zone from Door 1.		
L1: Card or			
Common Password TZ	Display the Card or Common Password Time Zone from Door 1.		
Lock Release TZ	Display the Lock Release Time Zone from Door 1.		
Exit Button TZ	Display the Exit Button TZ from Door 1.		
APB IN/OUT	Display the Anti Pass Back Level from Door 1, APB level : 0-255 for door IN/OUT.		
Multiple-Door Interlocking	Display the Dual Interlocking function from Door 1, "Enabled" or "Disabled".		
Remote Grant	Display the Remote Grant function from Door 1, "Enabled" or		
Needed	"Disabled". Disabled Time from Deer 1 1 (5525 seconds)		
Lock Release Time	Display the Door Lock Release Time from Door 1, 1 – 65535 seconds		
(Open Delay Time)	allowed and 10 seconds = default.		
Door Open Delay Time	Display the Door Open Delay Time from Door 1, 10 seconds = default.		
Still Open Delay Time	Set a time period (0~255 seconds) to adjust door sensor/relay reaction		

	Set door access method with: Deactivated (Default)/Registered/FC/All			
	Deactivated =Default=Access Authority based on normal setup.			
		,		
	Registered: Users who have	we been registered to system can access the door		
	FC: Users may access doo	or by punching card programmed with Facility		
	Code and preset on SEMA	AC-D1 system. SEMAC-D1 system will verify		
	only FC (Facility code).			
	All: User may access door	by any kind of RFID cards		
		▲		
Degrade Mode	Uni Setup			
Degrade Mode	Wiegand Input :	Format 34 Bits ✓ (Default: 34 Bits)		
	Connection with Software :	TCP Mode Realtime(Client) (Default: Realtime Mode)		
	Access Log Password :	● ON ○ OFF		
	Facility Code(2 bytes in Decimal) :	1: 0 2: 0 3: 0 4: 0 5: 0		
		6: 0 7: 0 8: 0 9: 0 10: 0		
	DEC/HEX:	● DEC ○ HEX		
	Card Format:	Raw Data ○ Facility Code+ID		
	LOGO_CONTROLLER:	● Default ○ OFF		
		SAVE		
Too	,			
Log	Select the Access Log to be Recorded or Ignored and the Door Sensor			
Recorded/Sensor	Mode on Door 1.			
Mode	Wide on Door 1.			
Door 1 (on top)	Click "Door 1" to enter the "Door 1 Setting" screen.			

Door 1 Setting

First Admin Card IN Time Zone: 000 Deactivate V Multiple Badge+Admin Password Time Zone: 000 Deactivate 🗸 Double V 000 Deactivate V Double V Multiple Badge+Personal Password Time Zone : 000 Deactivate ✓ 000 Deactivate V Double ∨ Double V Multiple Badge Time Zone: 000 Deactivate > Double ✓ 000 Deactivate V Double ✓ Card+Admin Password Time Zone: 000 Deactivate ✓ 000 Deactivate ✓ Admin Password Time Zone: 000 Deactivate V 000 Deactivate V Card+Personal Password Time Zone : 000 Deactivate V 000 Deactivate V Password Time Zone: 000 Deactivate V 000 Deactivate ✓ 000 Deactivate ∨ 000 Deactivate ✓ Card Only Time Zone: Card or Password Time Zone: 001 Any Time 001 Any Time Lock Release Time Zone: 000 Deactivate ∨ First Card No Need ∨ Exit Button TZ: 001 Any Time Anti Pass Back Level: IN: 0 OUT:0 (0 - 255)Remote Grant Only: Disabled V Lock Release Time: 10 Sec (1 - 65535, 10 = default) Door Open Delay Time: 10 Sec (1 - 65535, 10 = default) Access Log: Recorded V Door Sensor Mode: N/A Still Open Delay Time: (1-255,0=default) Deactivate 🗸 Degrade Mode:



♦ Illustrations of Door 1 Setting in Door Setup

N Door 1 Cotting			
▶ Door 1 Setting	Cotamble time and of First Administrator's Conditions of the desired		
First Admin Card IN Time Zone	Set up the time zone of First Administrator's Card to open the door as the bypass time zone of Door 1 (default—"000 Deactivate"). When this time zone is chosen, the user can only use the card of Administrator to scan/sweep the controller first and the other users may enter Door 1. Nobody may enter without using this First Admin Card to scan the controller of Door 1 in advance. **Should the user's bypass time zone level is L10, he/she may access by scanning the card and enter the Door 1 directly; however when the bypass time zone setup of Door 1 is" Lock Release Time Zone ", the user may access directly without any limitation.		
Multiple Badge +Admin Password Time Zone	Set up the Multiple Badge + Administrator Password time zone as the bypass time zone of Door 1 (default—"000 Deactivate"). Before setting this time zone, you must choose the function of "Multi Badge Group "to come to the "Multi Badge Group " screen and give the user ID in this time zone, max. 3 user IDs allowed; the user needs both 2 or 3 user ID cards and the Administrator's password to enter the Door 1 successfully. No any order limitation for scanning the cards first or enter the password first. You may scan the cards first then enter the password, or in reverse order. **Should the user's bypass time zone level is L9~L10, he/she may access by scanning the card and enter the Door 1 directly; however		
	when the bypass time zone setup of Door 1 is Lock Release Time Zone ", the user may access directly without any limitation.		
	Set up the Multiple Badge + Personal Password time zone as the bypass time zone of Door 1 (default–000 Deactivate"). Before setting this time zone, you must choose the function of "Multi Badge Group" to come to the "Multi Badge Group" screen and give the user ID in this time zone, max. 3 user IDs allowed; the user needs both 2 or 3 user ID cards and the Personal password to enter the Door 1 successfully. No any order limitation for scanning the cards first or		
Multiple Badge	enter the password first. You may scan the cards first then enter the		
+Personal Password	password, or in reverse order. However, the order of personal		
Time Zone	passwords will make differences. For example, there are two cards + passwords belonged to A and B. Should A card be scanned first, A has to enter his/her password first. Password B is not allowed to be entered before Password A. ** Should the user's bypass time zone level is L8~L10, he/she may access by scanning the card and enter the Door 1 directly; however when the bypass time zone setup of Door 1 is" Lock Release Time Zone ", the user may access directly without any limitation.		


Multiple Badge Time Zone	Set up the Multiple Badge time zone as the bypass time zone of Door 1 (default—"000 Deactivate"). Before setting this time zone, you must choose the function of "Multi Badge Group" to come to the "Multi Badge Group" screen and give the user ID in this time zone, max. 3 user IDs allowed; the user needs both 2 or 3 user ID cards to enter the Door 1 successfully. No any order limitation for scanning the cards ** Should the user's bypass time zone level is L7~L10, he/she may access by scanning the card and enter the Door 1 directly; however when the bypass time zone setup of Door 1 is" Lock Release Time Zone ", the user may access directly without any limitation.
Card +Admin Password Time Zone	Set up the Card + Admin Password time zone as the bypass time zone of Door 1 (default—" 000 Deactivate"). The user has to scan the card and enter the Admin Password to access Door 1. No any order limitation for scanning the cards first or enter the password first. ** Should the user's bypass time zone level is L6~L10, he/she may access by scanning the card and enter the Door 1 directly; however when the bypass time zone setup of Door 1 is" Lock Release Time Zone ", the user may access directly without any limitation.
Admin Password Time Zone	Set up the Admin Password time zone as the bypass time zone of Door 1 (default—"000 Deactivate"). The user has to enter the Admin Password to access Door 1. ** Should the user's bypass time zone level is L5~L10, he/she may access by scanning the card and enter Door 1 directly; however when the bypass time zone setup of Door 1 is" Lock Release Time Zone ", the user may access directly without any limitation.
Card +Personal Password Time Zone	Set up the Card+ Personal Password time zone as the bypass time zone of Door 1 (default—"000 Deactivate"). The user has to scan the card and enter the Personal Password to access Door 1. No any order limitation for scanning the cards first or enter the password first. Should the user's bypass time zone level is L4~L10, he/she may access by scanning the card and enter Door 1 directly; however when the bypass time zone setup of Door 1 is" Lock Release Time Zone ", the user may access directly without any limitation.
Password Time Zone	Set up the Common Password time zone as the bypass time zone of Door 1 (default—"000 Deactivate"). The user has to enter the Common Password to access Door 1. ** Should the user's bypass time zone level is L3~L10, he/she may access by scanning the card and enter Door 1 directly; however when the bypass time zone setup of Door 1 is" Lock Release Time Zone ", the user may access directly without any limitation.

	Set up the Card Only time zone as the bypass time zone of Door 1
	(default –" 000 Deactivate"). The user has to scan the card to access
	Door 1.
Card Only Time Zone	Should the user's bypass time zone level is L2~L10, he/she may
Card Omy Time Zone	access by scanning the card and enter Door 1 directly; however when
	the bypass time zone setup of Door 1 is" Lock Release Time Zone ",
	the user may access directly without any limitation.
	Set up the Card or Common Password time zone as the bypass time
	zone of Door 1 (default as "001 Any Time"). The user has to scan the
	card or enter the Common Password to access Door 1.
Card or Password	
Time Zone	Should the user's bypass time zone level is L1~L10, he/she may
	access by scanning the card and enter Door 1 directly; however when
	the bypass time zone setup of Door 1 is "Lock Release Time Zone",
	the user may access directly without any limitation.
	Set up the Lock Release time zone as the bypass time zone of Door 1
Lock Release Time	(default—"000 Deactivate"). The user needs no any verification to
Zone	access Door 1; however, if the "First Card" setup is "Needed", the use
	has to scan a "First Card"in advance to activate the "Lock Release
	Time Zone" function.
Exit Button TZ	Set up the Exit Button time zone as the bypass time zone of Door 1,
	supporting "OUT "for Door 1 only (default as " 001 Any Time").
Anti Pass Back Level	Set up the Anti Pass Back Level of " IN " and " OUT " for Door 1, level
	0~255.
D. H. J. J. J.	Disable or Enable the "Dual Interlocking" function. Upon this function
Dual Interlocking	enabled, the user enters Door 1 and cannot enter the other door until
	Door 1 close.
	Disable or Enable the "Remote Grant" access control function. Upon
Remote Grant	this function enabled, the Software will take a remote control over the
	door's open or close.
Lock Release Time	Set up the "Lock Release Time", default as 10 seconds.
Door Open Delay Time	Set up "Door Open Delay Time", default as 10 seconds.
	Set up "Ignored" or "Recorded" the Access Log (default as
A T / D	"Recorded")
Access Log / Door	Set up Door Sensor Mode, options for "Normal Open/Close" or
Sensor	"Circuit Short/Open" (default as "Normal Open/Close"). Should it is
Mode	"Circuit Short/Open" selected, the Door 1 Setting will display "Circuit
	Short" when the door is in short circuit or broken.
g.m.o. = -	Set a time from 0~255 seconds for adjusting door sensor/relay reaction
Still Open Delay Time time difference	
Degrade Mode	Select system verification mode: Deactivated/Registered/FC/ALL

Remarks: Same setting for door 1

♦ Remote Control

Select and Click "Remote Control" on the left side of the Main Window, you'll see the "Door Status Monitoring /Security Bypass" screen as below:



♦ Illustrations of Door Status Monitoring/Security Bypass

▶ Door Status Mor	nitoring	
	Display the most updated status from Door 1.	
D. G. G.	No light Displayed indicated no response	
	Green light indicated door closed	
Door Status	Yellow light indicated door opened	
	Red light indicated abnormal status (for example, short circuit, intruded,	
	door opened too long, and so on)	
Fire Alarm	Display whether the "Fire Alarm Detection "function enabled or not.	
Detection	Display whether the The Alaim Detection function enabled of not.	
Defense State	Display whether the "Defense State "function enabled or not.	
► Security Bypass		
State	Display the "Security Bypass State" from Door 1, Normal/Force	
State	Open/Force Close.	
Door 1	Tick the box of Door 1 to monitor the Security Bypass of Door 1.	
Select All	Click this button and tick all the boxes from Door 1.	
Cancel All	Click this button and cancel all the ticks of the boxes before Door 1.	
Pulse Open Door	Click this button to open the door(s) remotely for all the door(s) ticked.	
Tuise Open Door	This function works when the Security Bypass state is normal.	
	Click this button to make a force close on the door(s) remotely for all the	
Force Close	door(s) ticked. Hence the state(s) of all the door(s) ticked	
Torce Close	will display "Force Close". Even the RFID card scanned through the	
	door(s), you may not access the door(s).	
Back to Normal	Click this button to remotely restore all the door(s) ticked back to normal	
Duck to Horman	Security Bypass status.	
	Click this button to make a force open on the door(s) remotely for all the	
Force Open	door(s) ticked. Hence the state(s) of all the door(s) ticked	
rozee open	will display "Force Open " and the door(s) will stay at "Lock Release"	
	status.	
Emergency Open	Click this button to make a force open on all the door(s) remotely and the	
All Door	door(s) will stay at "Lock Release" status.	
Emergency Close	Click this button to make a force close on all the door(s) remotely and the	
All Door	door(s) cannot be accessed normally.	
Fire Alarm	Click this button to activate the "Fire Alarm Detection" function and the	
Detection ON	door(s) state will display "on".	
Fire Alarm	Click this button to deactivate the "Fire Alarm Detection" function and the	
Detection OFF	door(s) state will display "off".	
Alarm OFF	Click this button to deactivate all the Alarms already triggered.	

♦ Event Handle

Select "Event Handle" on the left side of the Main Window, you'll see the "Event Handle" screen as below:

Event Handle

	Hard Alarm	Soft Alarm1	Soft Alarm2	IP Camera
Latched Time(Second)	0	0	0	0
Event				
Unregistered User	0	0	0	0
Deactivated User	0	0	0	0
Not Allowed Door	0	0	0	0
Time Zone Violation	0	0	0	0
Expired User	0	0	0	0
Anti Pass Back Violation	0	0	0	0
Door open too long	0	0	0	0
Door Intruded	0	0	0	0
Duress Alarm On	0	0	0	0
Fire Alarm On	0	0	0	0



♦ Illustration of Event Handle

► Event Type				
	Set a latched time (0~65535 seconds) for Hard Alarm/Soft Alarm 1/Soft			
	Alarm 2/IP Camera event trigger.			
	Hard Alarm : Set Event to Trigger Hard Alarm			
	Hard Alarm			
	Latched Time 0 (sec,Max 65535 : 0 means unlimited)			
	☐ Unregistered User ☐ Deactivated User ☐ Not Allowed Door ☐ Time Zone Violation ☐ Expired User			
	☐ Anti Pass Back Violation ☐ Door open too long ☐ Door Intruded ☐ Duress Alarm On ☐ Fire Alarm On			
	Soft Alarm 1 / Soft Alarm 2 :			
	Soft Alarm1			
Latched Time	Latched Time 0 (sec,Max 65535 : 0 means unlimited)			
	☐ Unregistered User ☐ Deactivated User ☐ Not Allowed Door ☐ Time Zone Violation ☐ Expired User ☐ Anti Pass Back Violation ☐ Door open too long ☐ Door Intruded ☐ Duress Alarm On ☐ Fire Alarm On			
	Set			
	Soft Alarm2			
	Latabad Time (0)			
	Latched Time 0 (sec,Max 65535 : 0 means unlimited) Unregistered User Deactivated User Not Allowed Door Time Zone Violation Expired User Anti Pass Back Violation Door open too long Door Intruded Duress Alarm On Set			
	IP Camera: Even trigger type from IP Camera			
	IP Camera			
	☐ Unregistered User ☐ Deactivated User ☐ Not Allowed Door ☐ Time Zone Violation ☐ Expired User			
	☐ Anti Pass Back Violation ☐ Door open too long ☐ Door Intruded ☐ Duress Alarm On ☐ Fire Alarm On Set			
	1 · It will be listed in the "Drop Down Menu". When it's selected and the			
	user unregistered, one unregistered record will be shown on the "Access			
	Log "screen (referring to the sample as below); if the event level equal to			
	or higher than the "Alarm Trigger Level", the Relay will be triggered and			
Unregistered	the E-mail will alert when "E-mail Alerts "is configured and one alert			
User	e-mail will be sent out.			
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by			
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security			
	Bypass" screen of "Remote Control" function, default level = 0, referring			
	to the below picture :			

	1 · It will be listed in the "Drop Down Menu". When it's selected and the			
	user deactivated, one "Deactivated" message will be recorded and shown			
	on the "Access Log"screen (referring to the example as below); if the			
Descripted	event level equal to or higher than the "Alarm Trigger Level", the Relay			
Deactivated	will be triggered and the E-mail will alert when "E-mail Alerts"is			
User	configured and one alert e-mail will be sent out.			
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by			
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security			
	Bypass" screen of "Remote Control" function, default level = 0.			
	1 · It will be listed in the "Drop Down Menu". When it's selected and the			
	user's "Group" setting different from the Door Settings, one			
	"DISALLOWED DOOR" message will be recorded and shown on the			
	" Access Log "screen; if the event level equal to or higher than the			
	"Alarm Trigger Level", the Relay will be triggered and the E-mail will			
Not Allowed	alert when "E-mail Alerts "is configured and one alert e-mail will be sent out. (referring to below examples of user's Group setting and Door			
Door				
	setting) (steps : Access Log→Click the User ID→Enter the "User			
	RECORD" screen to modify the configuration of "Group")			
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by			
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security			
	Bypass" screen of "Remote Control" function, default level = 0.			
	1 \ It will be listed in the "Drop Down Menu". When it's selected and the			
	"Multi-Badge " verification failed, one "(1)DOUBLE REJ" message will			
	be recorded and shown on the " Access Log" screen (referring to the			
Multi-Badge	example as below); if the event level equal to or higher than the" Alarm			
Violation	Trigger Level", the Relay will be triggered and the E-mail will alert when			
Violation	"E-mail Alerts "is configured and one alert e-mail will be sent out.			
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by			
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security			
	Bypass" screen of "Remote Control" function, default level = 0.			

	1 · It will be listed in the "Drop Down Menu". When it's selected and the				
	user's "Group" setting different from the Door Settings, one "(1)Open				
	Time Error "message will be recorded and shown on the Access				
	Log "screen (referring to the example as below); if the event level equal to				
Time Zone	or higher than the "Alarm Trigger Level", the Relay will be triggered and the E-mail will alert when "E-mail Alerts "is configured and one alert				
Violation					
7101411011	e-mail will be sent out.				
	2 • When the "Latched Time : 0", the alert can only be lifted/stopped by				
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security				
	Bypass" screen of "Remote Control" function, default level = 0.				
	1 · It will be listed in the "Drop Down Menu". When it's selected and the				
	user's "Expiry Date" overdue, one "(1)EXPIRED "message will be				
	recorded and shown on the Access Log "screen (referring to the example				
	as below); if the event level equal to or higher than the" Alarm Trigger				
Expired User	Level", the Relay will be triggered and the E-mail will alert when "E-mail				
	Alerts "is configured and one alert e-mail will be sent out.				
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by				
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security				
	Bypass" screen of "Remote Control" function, default level = 0.				
	1 · It will be listed in the "Drop Down Menu". When it's selected and the				
	doors with "Anti Pass Back Level "configuration, one "(1)ANTI_PB				
	REJ "message will be recorded and shown on the Access Log "screen				
	(referring to the example as below); if the event level equal to or higher				
Anti Pass Back	than the" Alarm Trigger Level", the Relay will be triggered and the E-mail				
Violation	will alert when "E-mail Alerts "is configured and one alert e-mail will be				
Violation	sent out.				
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by				
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security				
	Bypass" screen of "Remote Control" function, default level = 0.				
	% Only 1 Door (2 way) is supported with this function.				

	1 · It will be listed in the "Drop Down Menu". When it's selected and the					
	door closes over the time set after the user card being scanned, one					
	"(O)Open too long "message will be recorded and shown on the Access					
	Log "screen (referring to the example as below); if the event level equal to					
Door open too	or higher than the" Alarm Trigger Level", the Relay will be triggered and					
long	the E-mail will alert when "E-mail Alerts "is configured and one alert					
	e-mail will be sent out.					
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by					
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security					
	Bypass" screen of "Remote Control" function, default level = 0.					
	1 · It will be listed in the "Drop Down Menu". When it's selected and the					
	door is accessed forcibly and abnormally, one "(O) DOOR INTRUDED"					
	message will be shown on the Access Log "screen (referring to the					
	example as below); if the event level equal to or higher than the "Alarm					
Door Intruded	Trigger Level", the Relay will be triggered and the E-mail will alert when					
	"E-mail Alerts "is configured and one alert e-mail will be sent out.					
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by					
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security					
	Bypass" screen of "Remote Control" function, default level = 4.					
	1 · It will be listed in the "Drop Down Menu". When it's selected and the					
	"Duress Alarm "of a door is triggered by the user (note : you have to key					
	in the "Anti Duress Password" and press "ENT "before scanning the user					
	card), one "ANTI DURESS" message will be shown on the Access					
Duress Alarm	Log "screen; if the event level equal to or higher than the "Alarm Trigger					
On	Level", the Relay will be triggered and the E-mail will alert when "E-mail					
	Alerts "is configured and one alert e-mail will be sent out.					
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by					
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security					
	Bypass" screen of "Remote Control" function, default level = 4.					
	1 • It will be listed in the "Drop Down Menu". When it's selected and if the					
	"Fire Alarm "is triggered, one "FIRE ALARM" message will be recorded					
	and shown on the Access Log "screen; if the event level equal to or highe					
	than the "Alarm Trigger Level", the Relay will be triggered and the					
Fire Alarm On	E-mail will alert when "E-mail Alerts "is configured and one alert e-mail					
	will be sent out.					
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by					
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security					
	Bypass" screen of "Remote Control" function, default level = 5.					

♦ Multi Badge Group

Select and Click "Multi Badge Group" on the left side of the Main Window, you'll see the "Multi Badge Group" screen as below:

Multi Badge Group

Multi Badge Group	User ID 1	User ID 2	User ID 3
1.			
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			
set			

♦ Illustration of Multi Badge Group

► Multi Badge Group		
Multi Badge Group	Iti Badge Group Max. 10 Groups to be set.	
User ID 1	Enter the User ID 1 for Multi Badge Group.	
User ID 2	Enter the User ID 2 for Multi Badge Group.	
User ID 3	Enter the User ID 3 for Multi Badge Group.	
Set (button)	Save all the configurations.	

> TOOLS

♦ IP Camera

Select "IP Camera" on the left side of the Main Window, you'll see the "IP Camera" screen as the following example:



♦ Illustration of IP Camera

▶ IP Camera	
IP Camera 1	Enter the IP address of IP Camera 1 to be lined.
Door 1	Display the captured and the most updated picture of Door 1.
SET (button)	Save all the configurations.
Refresh (button)	Refresh the WEB page of IP Camera.

♦ Backup

SEMAC-D system can be backup for restore to system again by selecting:

Database/User Data/User list, as below:

Backup

Tips:

This command will export the User Registry data for backup purpose.

● Database(database.cfg) ○ User Data(userdata.cfg) ○ User List(userlist.txt)

BACKUP

♦ Restore

SEMAC-D system can be backup and restore to SEMAC-D again. Only Database/User List available.

RESTORE / IMPORT

Select a File to Restore / Import : 瀏覽... ● Database(database.cfg/userdata.cfg) ○ User List(userlist.txt) (It may takes few minutes to restore the database.) Restore Reboot Select "Reboot" on the left side of the Main Window, you'll see the "Reboot System" screen as below: **Reboot System** REBOOT

♦ Illustration of Reboot

▶ Button	
Reboot	Reboot the SEMAC-D1, similar to warm boot a computer.

♦ Upgrade Firmware

Select "Upgrade FIRMWARE" on the left side of the Main Window, you'll see the "FIRMWARE UPGRADE" screen as below:

FIRMWAVE UPGRADE

Warning: Upgrade must	NOT be interrupted	
Please select a file to upgrade :	[瀏覽]	UPGRADE

♦ Illustration of Upgrade Firmware

► Steps

Press button "Browse" to search your firmware to be upgraded.

Press button "Upgrade" to execute the firmware upgrade action.

► Note

Please upgrade the "System Code" first then upgrade "WEB code".

♦ Reset

Select "Reset" on the left side of the Main Window, you'll see the "Reset" screen as below:

Reset

☐ User Data ☐ Access Logs ☐ Group ☐ Time Zone ☐ Time Set ☐ Holiday SELECT ALL DELETE	☐ System Logs
Reset System to Factory Default - Factory Default	

♦ Illustration of Reset

▶ Data Reset		
User Data	Tick the box before "User Data" and Click "DELETE" button to	
	delete all the User Data.	
Access Log	Tick the box before "Access Log" and Click "DELETE" button	
	to delete all the Access Logs.	
Group	Tick the box before "Group" and Click "DELETE" button	
	to delete all the Groups.	
Time Zone	Tick the box before "Time Zone" and Click "DELETE" button	
	to delete all the Time Zone configurations.	
Time Set	Tick the box before "Time Set" and Click "DELETE" button	
	to delete all the Time Set configurations.	
Holiday	Tick the box before "Holiday" and Click "DELETE" button	
	to delete all the Holiday configurations.	
System Logs	Tick the box before "System Logs" and Click"DELETE" button	
	to delete all the System Logs.	
▶ Button		
Select All	Tick the box before above item.	
Delete	Delete above item(s) selected.	
Steps:		
1 \ Tick the item above to be deleted.		
2 · Click button "Delete".		
► Reset System to Factory Default		
Factory Default	Execute this command to restore the system back to the factory	
	default.	
		